



## SECTION A-A



SECTION B-B

## GENERAL NOTES

- These dimensions are based on a 6"
  curb height, and shall be proportionally adjusted for other curb heights.
- (2) A 3'-0 minimum width ramp may be used when existing space prohibits the construction of the 4'-0 wide ramp.
- (3) The bottom edge of the curb ramp shall be flush with the edge of the adjacent pavement and gutter line.
- (4) Landing areas at the top of curb ramps shall have maximum cross slope of 1:50 in any direction. Where site infeasibility on a 3R project precludes a landing slope of 1:50 in any direction, the slope perpendicular to the curb face shall not exceed 1:50.
- (5) If site infeasibility on a 3R project precludes construction as shown, the landing width may be decreased to 3'-0 minimum and the running slope of the curb ramp may be increased to a maximum of 10:1 for 6" of rise.



DESIGN STANDARDS ENGINEER ORIGINALLY APPROVED

1-02-97